

INDUSTRIAL COMPONENT DATA

1SAL247493R9912 ABB MC2C310ARWDD-RAIL Mini Contactor

Brand: ABB | Manufacturer Part Number: 1SAL247493R9912



Number of Main Contacts NO 3
Number of Main Contacts NC 0
Number of Auxiliary Contacts NO 1
Number of Auxiliary Contacts NC 0
Number of Poles 3P
Standards IEC/EN 60947-1
IEC/EN 60947-4-1
IEC/EN 60947-5-1
UL 60947-1
UL 60947-4-1
UL 60947-5-1
Rated Operational Voltage Auxiliary Circuit 690 V AC
Auxiliary Circuit 440 V DC
Main Circuit 690 V AC
Main Circuit 440 V DC
Rated Frequency (f) Auxiliary Circuit 50 Hz
Auxiliary Circuit 60 Hz
Auxiliary Circuit DC
Control Circuit DC
Main Circuit 50 Hz
Main Circuit 60 Hz
Main Circuit DC
Conventional Free-air Thermal Current (I_{th}) Auxiliary Circuit 10 A
Main Circuit 20 A
Rated Operational Current AC-1 (I_e) (690 V) 55 °C 20 A
(690 V) 70 °C 16 A
(230 V) 55 °C 20 A
(230 V) 70 °C 16 A
(400 V) 55 °C 20 A
(400 V) 70 °C 16 A
(500 V) 55 °C 20 A
(500 V) 70 °C 16 A
Rated Operational Current AC-3 (I_e) (230 V) 55°C 12 A
(400 V) 55 °C 12 A
(500 V) 55 °C 10 A
(690 V) NO 55°C 5 A
Rated Operational Current AC-15 (I_e) (240 V) 6 A
(400 V) 4 A
(500 V) 2.5 A
(690 V) 1.5 A
Rated Operational Current DC-13 (I_e) (24 V) 5 A
(48 V) 2.5 A
(125 V) 0.55 A
(250 V) 0.3 A
(440 V) 0.15 A
Rated Operation...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send ABB / 1SAL247493R9912 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.