

Technical

Type of Residual Current Type B
Test Voltage (Ut) 170 ... 253 V
Dielectric Test Voltage 2500 kV
Impulse Current I (max, 8 / 20 μ s) 3000 A
Maximum Surge Current 3 kA
Leakage Current Type B
Electrical Endurance 10000 cycle
Mechanical Endurance 20000 cycle
Number of Poles 4P
Number of Modular Spacings per DIN Rail 4
Operating Characteristic 10ms Delay (High Immunity)
Position of Neutral Terminals Right
Tightening Torque 2.8 N·m
Delay Time (?) 10 ms
Accessory Type Auxiliary contact
Signal contact/auxiliary contact
Shunt trip
Undervoltage release
Overvoltage release
Motor operating device
Auto reclosing unit
Actuator Type Toggle - Insulation group I - II, RAL 5015
Housing Type Insulation group I - II, RAL 7035
Screw Terminal Type Failsafe Bi-directional Cylinder...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send ABB / 2CSF204568R1400 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.