



Dimension Diagram GJL1200447F0001

Technical

Number of Main Contacts NO 3

Number of Main Contacts NC 0

Number of Auxiliary Contacts NO 1

Number of Auxiliary Contacts NC 0

Number of Poles 3P

Standards IEC/EN 60947-1

IEC/EN 60947-4-1

IEC/EN 60947-5-1

UL 60947-1

UL 60947-4-1

IEC 60335-2-40 A2L

Rated Operational Voltage Auxiliary Circuit 690 V AC

Auxiliary Circuit 250 V DC

Main Circuit 690 V AC

Main Circuit 220 V DC

Rated Frequency (f) Control Circuit 400 Hz

Control Circuit 50 Hz

Control Circuit 60 Hz

Main Circuit 60 Hz

Main Circuit 50 Hz

Main Circuit DC

Conventional Free-air Thermal Current (I<sub>th</sub>) Main Circuit 20 A

Rated Operational Current AC-1 (I<sub>e</sub>) (220 / 240 V) 40 °C 20 A

(220 / 240 V) 55 °C 16 A

(380 / 440 V) 40 °C 20 A

(380 / 440 V) 55 °C 16 A

(690 V) 40 °C 6 A

(690 V) 55 °C 6 A

Rated Operational Current AC-3 (I<sub>e</sub>) (230 V) 55°C 9 A

(400 V) 55 °C 9 A

(500 V) 55 °C 6.5 A

(690 V) NO 55°C 3.5 A

Rated Operational Current AC-15 (I<sub>e</sub>) (440 V AC) 3 A

(24 V) 4 A

(120 V) 4 A

(240 V) 4 A

(500 V) 2 A

(380 / 400 V) 3 A

Rated Operational Current DC-13 (I<sub>e</sub>) (24 V) 2.5 A

(110 V) 0.7 A

(220 / 240 V) 0.4 A

Rated Operational Po...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send ABB / GJL1211911R8104 with the required quantity to [info@electricaonline.com](mailto:info@electricaonline.com) or use [electricaonline.com/request-quote](https://electricaonline.com/request-quote).

### GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.