

INDUSTRIAL COMPONENT DATA

92275 LUXOMAT Occupancy detector PD4/DIM/DALI/DSI/FC 230V

Brand: B.E.G. LUXOMAT | Manufacturer Part Number: 92275



Manufacturer	B.E.G. LUXOMAT
MPN / Reference	92275
Catalog number	92275
Category	KNX - Intelligent building systems
Minimum order	1 unit
Document ID	EO-DF5F4E2E62
Generated	2026-08-03

Product Overview

92275 LUXOMAT Occupancy detector PD4/DIM/DALI/DSI/FC 230V

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

B.E.G. LUXOMAT > Motion and occupancy detectors - B.E.G. LUXOMAT > Ceiling-mounted with daylight appraisal

Additional Product Information

Features

Designation Value

Voltage: 110 - 240 V AC 50 / 60 Hz

Dimensions: Ø 97 x 103 mm

Power consumption: approx. 1 W

Detection area: horizontal 360° (Ceiling mounting)

Range: max. Ø 24 m across

max. Ø 8 m towards

max. Ø 6.4 m seated

Monitored area (tangential movement): 450 m² / 2.5 m mounting height

Mounting height min./max./recommended: 2 m / 10 m / 2.5 m

Degree / class of protection: IP20 / Class II

Ambient temperature: -25 °C to +50 °C

Housing: polycarbonate, UV-resistant

Material color: white mat, similar to RAL9010

Channel 1 (lighting control)

Designation Value

DALI output: up to 50 DALI / DSI-EB

Follow-up time: 1 min - 30 min

Orientation light: 10 - 30 % / OFF / 5 min - 60 min / ?

Brightness set value: 10 - 2000 Lux

Light measuring: Mixed light measuring

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send B.E.G. LUXOMAT / 92275 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.