

INDUSTRIAL COMPONENT DATA**92755 LUXOMAT PD4 TRIO DALI FC**

Brand: B.E.G. LUXOMAT | Manufacturer Part Number: 92755



Manufacturer	B.E.G. LUXOMAT
MPN / Reference	92755
Catalog number	92755
Category	KNX - Intelligent building systems
Minimum order	1 unit
Document ID	EO-B05C14E90F
Generated	2026-08-03

Product Overview

92755 LUXOMAT PD4 TRIO DALI FC

STRUCTURED PRODUCT DATA**Technical Specifications**

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path

B.E.G. LUXOMAT > Motion and occupancy detectors - B.E.G. LUXOMAT > Ceiling-mounted with daylight appraisal

Additional Product Information**Features**

Designation Value

Voltage: 110 - 240 V AC 50 / 60 Hz

Dimensions: Ø 117 x 100 mm

Power consumption: approx. 2.2 W

Detection area: horizontal 360° (Ceiling mounting)

Range: max. Ø 24 m across

max. Ø 8 m towards

max. Ø 6.4 m seated

Monitored area (tangential movement): 450 m² / 2.5 m mounting height

Mounting height min./max./recommended: 2 m / 10 m / 2.5 m

Degree / class of protection: IP20 / Class II

Impact strength: IK04

Ambient temperature: -25 °C to +50 °C

Housing: polycarbonate, UV-resistant

Material color: white mat, similar to RAL9010

Channel 1 and Channel 2 (lighting control)

Designation Value

DALI output: up to 25 DALI / DSI-EB per channel

Orientation light: 10 - 30 % / OFF / 1 min - 60 min / ?

Channel 3 (lighting control)

Designation Value

Switching power: up to 10 DALI / DSI-EB

Channel 1 to channel 3

Designation Value

Follow-up time: 1 min - 60 min

Brightness set value: 40 - 1200 Lux

Light measuring: Mixed light measuring

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send B.E.G. LUXOMAT / 92755 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.