

INDUSTRIAL COMPONENT DATA

92938 LUXOMAT Occupancy detector PD9-DALI/DSI-GH-FC, white

Brand: B.E.G. LUXOMAT | Manufacturer Part Number: 92938



Manufacturer	B.E.G. LUXOMAT
MPN / Reference	92938
Catalog number	92938
Category	KNX - Intelligent building systems
Minimum order	1 unit
Document ID	EO-2A6848612E
Generated	2026-08-03

Product Overview

92938 LUXOMAT Occupancy detector PD9-DALI/DSI-GH-FC, white

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path B.E.G. LUXOMAT > Motion and occupancy detectors - B.E.G. LUXOMAT > Ceiling-mounted with daylight appraisal

Additional Product Information

Features

Designation Value

Voltage: 110 - 240 V AC 50 / 60 Hz

Dimensions: Sensor head: Ø 45 x 41 mm, Power supply: 165 x 24 x 24 mm

Power consumption: approx. 1 W

Detection area: horizontal 360° (Ceiling mounting)

Range: max. Ø 3.5 m across

Monitored area (tangential movement): 9 m² / 6 m mounting height

Mounting height min./max./recommended: 5 m / 10 m / 6 m

Degree / class of protection: IP20 / Class II

Ambient temperature: -25 °C to +50 °C

Housing: polycarbonate, UV-resistant

Material color: white mat, similar to RAL9010

Cable length: 45 cm

Channel 1 (lighting control)

Designation Value

DALI output: up to 50 DALI / DSI-EB

Follow-up time: 1 min - 30 min

Orientation light: 10 - 30 % / OFF / 5 min - 60 min / ?

Brightness set value: 10 - 2000 Lux

Light measuring: Mixed light measuring

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send B.E.G. LUXOMAT / 92938 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.