

INDUSTRIAL COMPONENT DATA

L4330/230 BTCINO LL-RELAY NO/NC 10A/230V 1M ANTR

Brand: BTICINO | Manufacturer Part Number: L4330/230

PRODUCT IMAGE\n\nNOT
AVAILABLE

Manufacturer	BTICINO
MPN / Reference	L4330/230
Catalog number	L4330/230
Category	Switching relay
Minimum order	1 Pcs
Document ID	EO-8A7974247B
Generated	2026-08-04

Product Overview

LL-RELAY NO/NC 10A/230V 1M ANTR

Relay monostable LivingLight - 1 module - Anthracite

Livinglight monostable relay - 1mod - Anthracite

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path BTICINO > LIVINGLIGHT MECHANISMS

Additional Product Information

Product features

Relays monostables - Relay monostable acon contact NA/NC - 250 Vac 10 A resistive 4 A inductive cos phi 0,5 - 1 module -

Anthracite General characteristics

Livinglight - other mechanisms

ETIM for L4330/230 Relays (EC001437)

Feature Name

Feature Value

Height (EF000040)

44 mm

Degree of protection (IP) (EF005474)

IP40

Type of switch contact (EF003358)

Single contact

Drive, polarization (EF003355)

Polarity free
Drive, switching attitude (EF003356)
Mono stable
Voltage type for actuating (EF008242)
AC
With detachable clamps (EF003340)
No
Number of contacts as change-over contact (EF008257)
1
Type of electric connection (EF003961)
Screw connection
Depth (EF000049)
29 mm
Rated control supply voltage AC 50 Hz (EF003978)
135 V
Complete with socket (EF003359)
No
Width (EF000008)
22 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send BTICINO / L4330/230 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.