

INDUSTRIAL COMPONENT DATA

RGS1A60A92KKE CARLO GAVAZZI Some selected criteria system industrial housing rated current 76 100 AAC Nomina..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGS1A60A92KKE



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGS1A60A92KKE
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-E19519F7DD
Generated	2026-08-05

Product Overview

Some selected criteria system industrial housing rated current 76 - 100 AAC Nominal voltage 600 VAC Switching output mode Zero switching Number of poles 1 control AC & DC power connector screw Model SSR ITEM CODE RGS1A60A92KKE Other Current 90 AAC, 18000 A's Product Width 17.6mm
Single phase AC - Contactor without integrated varistor heatsink; Current 90A, 1600Vp I_{2t} high
1-pole panel mount SSR, E-layout, Zero-cross switching, Operating voltage (U_e): 42 - 660 Vac (1200 Vp), Rated current (I_e): 90 Aac, Control voltage (U_c): 20 - 275 Vac / 24 - 190 Vdc, Built-in overvoltage protection, High I_{2t}

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles1Rated current AC-5190 ARated current AC-53a18 AOperating voltage42 V ... 660 VControl voltage AC20 V ... 275 VControl voltage DC21.6 V ... 190 VPower connectionScrew with captive clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGS1A60A92KKE with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.