

INDUSTRIAL COMPONENT DATA

RGS1A60D92KGE CARLO GAVAZZI System: Panel Mount, Current rating category: 76 100 AAC, Rated voltage: 600 VAC..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGS1A60D92KGE



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGS1A60D92KGE
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-DDB0010D53
Generated	2026-08-02

Product Overview

System: Panel Mount, Current rating category: 76 - 100 AAC, Rated voltage: 600 VAC, Output switching mode: Zero Cross, Number of poles: 1, Control: DC - DIGITAL , Power connection: Box Clamp, Model: Solid State Relay, Item code: RGS1A60D92KGE, Current rating: 90 AAC, 18000 AÂ²s, Control input: 4 - 32 VDC, Product width: 17.6mm
Single phase AC - Contactor without integrated varistor heatsink; Current 90A, 1200Vp I_t high
1-pole panel mount SSR, E-layout, Zero-cross switching, Operating voltage (U_e): 42 - 660 Vac (1200 Vp), Rated current (I_e): 90 Aac, Control voltage (U_c): 4 - 32 Vdc, Built-in overvoltage protection, High I₂t

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles1Rated current AC-5190 ARated current AC-53a18 AOperating voltage42 V ... 660 VControl voltage AC0 V ... 0 VControl voltage DC4 V ... 32 VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGS1A60D92KGE with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.