

## INDUSTRIAL COMPONENT DATA

# CTD8S5001AXXX CARLO GAVAZZI Current Transformer

## Rev.4

Brand: CARLO GAVAZZI | Manufacturer Part Number: CTD8S5001AXXX



|                 |                     |
|-----------------|---------------------|
| Manufacturer    | CARLO GAVAZZI       |
| MPN / Reference | CTD8S5001AXXX       |
| Catalog number  | 10000               |
| Category        | Current transformer |
| Minimum order   | 1 Pcs               |
| Document ID     | EO-8BF405C6F7       |
| Generated       | 2026-08-03          |

### Product Overview

Current Transformer Rev.4

Current transformer, closed core

Split core Current transformer 500A/1A

## STRUCTURED PRODUCT DATA

### Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

### Classification & Catalog Path

Catalog path CARLO GAVAZZI &gt; Controls &gt; Digital Panel Meters and temperature

### Additional Product Information

## Specifications

Rated primary current500 AOutput1 AHole diameter31 mm (1.22 in)Max busbar width31 mm (1.22 in)Accuracy class1

ETIM for CTD8S5001AXXX Low-voltage industrial controls and switchgear (EC002048)

Feature Name

Feature Value

Model (EF000010)

Attachable current transformer

Rated primary current (EF007405)

500 A

Rated secondary current (EF007471)

1 A

Rated secondary apparent power (EF007470)

5 VA

Opening diameter (EF005153)

31 mm

Number of primary inputs (EF006947)

1

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / CTD8S5001AXXX with the required quantity to [info@electricaonline.com](mailto:info@electricaonline.com) or use [electricaonline.com/request-quote](https://electricaonline.com/request-quote).

### GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.