

INDUSTRIAL COMPONENT DATA

RGC1A60D32GEN CARLO GAVAZZI System: DIN-rail Mount, Current rating category: 26 50 AAC, Rated voltage: 600 V..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC1A60D32GEN



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC1A60D32GEN
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-2662E78991
Generated	2026-08-06

Product Overview

System: DIN-rail Mount, Current rating category: 26 - 50 AAC, Rated voltage: 600 VAC, Output switching mode: Zero Cross, Number of poles: 1, Control: DC - DIGITAL , Power connection: Box Clamp, Model: Solid State Switch with Fieldbus Interface, Current rating: 37AAC @ 40Â°C (104Â°F), integrated heatsink, Control input: 4 - 32 VDC, Product width: 17.8 x 110 x 130 mm

1P-Ssc-Dc In-Zc 600V 37A 1200Vp-E-Clp H-I2T Comm

1-pole DIN-rail mount SSR, Zero-cross switching, bus interface (NRG) for Real-time data (A, V, W, Hz, kWh, Hrs) and monitoring, Operating voltage (Ue): 42 - 660 Vac (1200 Vp), Rated current (Ie): 37 Aac, Control: 4-32 Vdc, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path CARLO GAVAZZI > Switches > Solid state relays

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles1Rated current AC-5137 AOperating voltage42 V ... 660 VControl voltage AC0 V ... 0 VControl voltage DC4 V ... 32 VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC1A60D32GEN with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.