

INDUSTRIAL COMPONENT DATA

RGC3A60D48KGE CARLO GAVAZZI System: Panel Mount, Current rating category: 26 50 AAC, Rated voltage: 600 VAC,...

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC3A60D48KGE



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC3A60D48KGE
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-C283DD8663
Generated	2026-08-05

Product Overview

System: Panel Mount, Current rating category: 26 - 50 AAC, Rated voltage: 600 VAC, Output switching mode: Zero Cross, Number of poles: 3, Control: DC - DIGITAL , Power connection: Box Clamp, Model: Solid State Contactor, Current rating: 48 AAC at 40Â°C (104Â°F), Control input: 5 - 32 VDC , Product width: 157 mm

3P-Ssc-Dc In-Zc 600V 3X48A 1200Vp-E-Srw In

3-pole DIN-rail mount SSR, Zero-cross switching, Operating voltage (Ue): 42 - 660 Vac (1200 Vp), Rated current (Ie): 48 Aac, Control voltage (Uc): 5 - 32 Vdc, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles3Rated current AC-5148 ARated current AC-53a23 AOperating voltage42 V ... 660 VControl voltage AC0 V ... 0 VControl voltage DC5 V ... 32 VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC3A60D48KGE with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.