

INDUSTRIAL COMPONENT DATA

VMUXUD1X CARLO GAVAZZI Selected parameters FUNCTION Energy Meters MOUNTING DIN Rail POWER SUPPLY 38 to 265VA..

Brand: CARLO GAVAZZI | Manufacturer Part Number: VMUXUD1X



Manufacturer	CARLO GAVAZZI
MPN / Reference	VMUXUD1X
Catalog number	10000
Category	Kilowatt-hour meter
Minimum order	1 Pcs
Document ID	EO-D159DC7704
Generated	2026-08-05

Product Overview

Selected parameters FUNCTION Energy Meters MOUNTING DIN Rail POWER SUPPLY 38 to 265VAC/DC OUTPUT DIGITAL INPUT DC/AC output (Opto Mosfet) INPUT TYPE DC CONNECTION Direct COMMUNICATION None Others RANGE None DISPLAY None VARIABLES None DIGITAL INPUTS None PULSE 1 ALARMS 1 ANALOGUE none Modular DC Power Analyzer, Universal Power Unit and Static Digital Output for VMU-E
Power supply and static output module for VMUE

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path CARLO GAVAZZI > Controls > Digital Panel Meters and temperature

Additional Product Information

Specifications

Static outputPulsePower supplyAuxiliary power supply 120 V ac; Auxiliary power supply 220-240 VacApprovals, marks, declarationsUKCA (UK)

ETIM for VMUXUD1X Meters (EC001506)

Feature Name

Feature Value

Pulse output (EF008838)

Electrical

Pulse rate (EF008840)

1000 Imp/kWh (kvarh)
Mounting method (EF000003)
DRA (DIN-rail adapter)
Width in number of modular spacings (EF002950)
1
Degree of protection (IP) (EF005474)
IP40

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / VMUXUD1X with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.