

INDUSTRIAL COMPONENT DATA

CTD8S2505AXXX CARLO GAVAZZI Selected parameters

PRIMARY CURRENT 150...300A PRIMARY TYPE Split-core

SECONDARY C..

Brand: CARLO GAVAZZI | Manufacturer Part Number: CTD8S2505AXXX



Manufacturer	CARLO GAVAZZI
MPN / Reference	CTD8S2505AXXX
Catalog number	150300
Category	Current transformer
Minimum order	1 Pcs
Document ID	EO-D31481F3B5
Generated	2026-08-04

Product Overview

Selected parameters PRIMARY CURRENT 150...300A PRIMARY TYPE Split-core SECONDARY CURRENT 5A Others
PRIMARY CURRENT 250A MAX BUS BAR SIZE 30x80mm MOUTING DIN-rail, Panel, Bus-bar
Current transformer, split core, Plate max. 30 x 80 mm.
Split core Current transformer 250A/5A

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **CARLO GAVAZZI > Controls > Digital Panel Meters and temperature**

Additional Product Information

Specifications

Rated primary current250 AOutput5 AHole diameter31 mm (1.22 in)Max busbar width31 mm (1.22 in)Accuracy class3
ETIM for CTD8S2505AXXX Low-voltage industrial controls and switchgear (EC002048)

Feature Name
Feature Value

Model (EF000010)

Attachable current transformer

Rated primary current (EF007405)

250 A

Rated secondary current (EF007471)

5 A

Rated secondary apparent power (EF007470)

2 VA

Opening diameter (EF005153)

31 mm

Number of primary inputs (EF006947)

1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / CTD8S2505AXXX with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.