


INDUSTRIAL COMPONENT DATA

TCD1M10080CMX CARLO GAVAZZI Selected parameters PRIMARY CURRENT 50...150A PRIMARY TYPE Triple split core SECON..

Brand: CARLO GAVAZZI | Manufacturer Part Number: TCD1M10080CMX



Manufacturer	CARLO GAVAZZI
MPN / Reference	TCD1M10080CMX
Catalog number	50150
Category	Current transformer
Minimum order	1 Pcs
Document ID	EO-CBDB8D9921
Generated	2026-08-04

Product Overview

Selected parameters PRIMARY CURRENT 50...150A PRIMARY TYPE Triple split core SECONDARY CURRENT For EM271-72D Others PRIMARY CURRENT 100A MAX BUS BAR SIZE 15.5mm Ø

Three-phase split core current transformer, for EM271 analyzer, Ø cable max. 16 mm.

3-phase split-core current sensors set for EM271 and ET272 Energy Meter, Primary Current 100A, Cable Mounting, Opening Diameter 15,76mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Controls > Digital Panel Meters and temperature
--------------	---

Additional Product Information

Specifications

Accuracy class0.5Multi-load sensor typesplit coreMulti-load sensor current inputs100AApprovals, marks, declarationsCE (Europe); cULus (North America); UKCA (UK)

ETIM for TCD1M10080CMX Low-voltage industrial controls and switchgear (EC002048)

Feature Name

Feature Value

Model (EF000010)

3-phase current converter set

Rated primary current (EF007405)

100 A

Opening diameter (EF005153)

15.7 mm

Snap mounting (EF007462)

Yes

Number of primary inputs (EF006947)

3

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / TCD1M10080CMX with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.