

INDUSTRIAL COMPONENT DATA

CTD9H7005AXXX CARLO GAVAZZI Selected parameters PRIMARY CURRENT 600...1200A PRIMARY TYPE Solid-core SECONDAR..

Brand: CARLO GAVAZZI | Manufacturer Part Number: CTD9H7005AXXX



Manufacturer	CARLO GAVAZZI
MPN / Reference	CTD9H7005AXXX
Catalog number	6001200
Category	Current transformer
Minimum order	1 Pcs
Document ID	EO-DCEF60E067
Generated	2026-08-01

Product Overview

Selected parameters PRIMARY CURRENT 600...1200A PRIMARY TYPE Solid-core SECONDARY CURRENT 5A Others
PRIMARY CURRENT 700A MAX BUS BAR SIZE 35x125mm MOUNTING DIN-rail, Panel, Bus-bar
Current transformer, closed core, max. 35X125 mm plate, horizontal mounting
Solid core Current transformer 700A/5A

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI
--------------	---------------

Additional Product Information

Specifications

Rated primary current700 AOutput5 AHole diameter36 mm (1.41 in)Max busbar width36 mm (1.41 in)Accuracy class0.5
ETIM for CTD9H7005AXXX Low-voltage industrial controls and switchgear (EC002048)

Feature Name

Feature Value

Model (EF000010)

Through-feed current converter

Rated primary current (EF007405)

700 A

Rated secondary current (EF007471)

5 A

Rated secondary apparent power (EF007470)

4 VA

Opening diameter (EF005153)

36 mm

Number of primary inputs (EF006947)

1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / CTD9H7005AXXX with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.