

INDUSTRIAL COMPONENT DATA

A74-1020 CARLO GAVAZZI Selected parameters PRIMARY CURRENT VALUE 20 A SECONDARY CURRENT / OUTPUT SIGNAL 4 Vp..

Brand: CARLO GAVAZZI | Manufacturer Part Number: A74-1020



Manufacturer	CARLO GAVAZZI
MPN / Reference	A74-1020
Catalog number	741020
Category	Current value transformer
Minimum order	1 Pcs
Document ID	EO-97C0320CC1
Generated	2026-08-02

Product Overview

Selected parameters PRIMARY CURRENT VALUE 20 A SECONDARY CURRENT / OUTPUT SIGNAL 4 Vp Others
SYSTEM 3-phase MOUNTING Panel HOUSING Solid-core
Three-phase current transformer
3-phase AC current transformer, input range up to 20 A AC, output 0.4 - 4Vp, wall mounting

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path CARLO GAVAZZI > Controls > Monitoring Relays and Measurement Current Transformers

Additional Product Information

Specifications

Adjustable settingsNoMax input current20 AAnalogue output0.4 - 2.83 VWall mounting/direct mountingYesRail mounting possibleNoWith approval according to ULYes
ETIM for A74-1020 Sensors (EC002475)
Feature Name
Feature Value
Initial value measuring range current (EF008198)
2 A
End value measuring range current (EF008266)
20 A

Type of analogy output (EF003958)

Other

Mounting method (EF000003)

Direct mounting

Integrated configuration function (EF003064)

No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / A74-1020 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.