

INDUSTRIAL COMPONENT DATA

E83-2050 CARLO GAVAZZI Selected parameters PRIMARY CURRENT VALUE 5 to 50 A SECONDARY CURRENT / OUTPUT SIGNAL..

Brand: CARLO GAVAZZI | Manufacturer Part Number: E83-2050



Manufacturer	CARLO GAVAZZI
MPN / Reference	E83-2050
Catalog number	832050
Category	Current value transformer
Minimum order	1 Pcs
Document ID	EO-AC2914F091
Generated	2026-08-04

Product Overview

Selected parameters PRIMARY CURRENT VALUE 5 to 50 A SECONDARY CURRENT / OUTPUT SIGNAL 4-20 mA

Others SYSTEM 1-phase MOUNTING DIN-rail (22,5 mm)/panel HOUSING Solid-core

Current transformer, closed core, Int. Output 4 - 20 mA DC (passive)

AC current transducer, 7 selectable input ranges up to 50 A AC, 4-20 mA DC analogue output, powered by loop voltage, DIN-rail or wall mounting

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path CARLO GAVAZZI > Controls > Monitoring Relays and Measurement Current Transformers

Additional Product Information

Specifications

Adjustable settingsYesMax input current50 AAnalogue output4-20 mAWall mounting/direct mountingYesRail mounting possibleYesWith approval according to ULYes

ETIM for E83-2050 Sensors (EC002475)

Feature Name

Feature Value

End value measuring range current (EF008266)

50 A

Type of analogy output (EF003958)

4-20 mA

Mounting method (EF000003)

DIN rail (top hat rail) 15 mm

Integrated configuration function (EF003064)

Yes

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / E83-2050 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.