

INDUSTRIAL COMPONENT DATA

RGC3A60A25GKEAM CARLO GAVAZZI Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 11 25 AAC RA..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC3A60A25GKEAM



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC3A60A25GKEAM
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-063F5FCBFF
Generated	2026-08-05

Product Overview

Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 11 - 25 AAC RATED VOLTAGE 600 VAC OUTPUT SWITCHING MODE Zero Cross NUMBER OF POLES 3 CONTROL AC POWER CONNECTION Screw MODEL Solid State Contactor with System Monitoring Others CURRENT RATING 25 AAC at 40°C (104°F) CONTROL INPUT 20-275 VAC PRODUCT WIDTH 70mm

AC three-phase relay. with heatsink, All-or-nothing switching, 3-phase, with monitoring

3-pole DIN-rail mount SSR, Zero-cross switching with monitoring, Operating voltage (Ue): 90 - 660 Vac (1200 Vp), Rated current (Ie): 25 Aac, Control voltage (Uc): 20 - 275 Vac / 24 - 190 Vdc, External supply: 90 - 250 Vac, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles3Rated current AC-5128 ARated current AC-53a11 AOperating voltage90 V ... 660 VControl voltage AC20 V ... 275 VControl voltage DC0 V ... 0 VPower connectionScrew with captive clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC3A60A25GKEAM with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.