

INDUSTRIAL COMPONENT DATA

RGC2A60D40GGEDM CARLO GAVAZZI Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 50 AAC RA..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC2A60D40GGEDM



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC2A60D40GGEDM
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-DBA9522C94
Generated	2026-08-04

Product Overview

Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 - 50 AAC RATED VOLTAGE 600 VAC OUTPUT SWITCHING MODE Zero Cross NUMBER OF POLES 2 CONTROL DC - DIGITAL POWER CONNECTION Box Clamp MODEL Solid State Contactor with System Monitoring Others CURRENT RATING 40 AAC at 40°C (104°F) CONTROL INPUT 5 - 32 VDC PRODUCT WIDTH 70mm

Three-phase relay CA. with heatsink, all-or-nothing switching, 2 phases + 1 direct, with monitoring 2-pole DIN-rail mount SSR, Zero-cross switching with monitoring, Operating voltage (Ue): 90 - 660 Vac (1200 Vp), Rated current (Ie): 40 Aac, Control voltage (Uc): 5 - 32 Vdc, External supply: 24 Vdc/Vac, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeZero crossNumber of poles2Rated current AC-5140 ARated current AC-53a16.5 AOperating voltage90 V ... 660 VControl voltage AC0 V ... 0 VControl voltage DC5 V ... 32 VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC2A60D40GGEDM with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.