

INDUSTRIAL COMPONENT DATA

RGC2P60V40C1DM CARLO GAVAZZI Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 50 AAC RAT..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC2P60V40C1DM



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC2P60V40C1DM
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-28C0E17519
Generated	2026-08-06

Product Overview

Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 - 50 AAC RATED VOLTAGE 600 VAC
OUTPUT SWITCHING MODE Full cycle control NUMBER OF POLES 2 CONTROL DC - ANALOGUE POWER
CONNECTION Box Clamp MODEL Proportional Controllers Others CURRENT RATING 40AAC @ 40°C (104°F) integrated
heatsink CONTROL INPUT 0...10VDC, 0...5VDC, 1...5VDC, potentiometer PRODUCT WIDTH 70mm
AC three-phase relay. with heatsink, Analog, 2 phases + 1 direct, with monitoring
2-pole DIN-rail mount SSR, Proportional control (1x FC) with monitoring, Operating voltage (Ue): 180 - 660 Vac (1200 Vp),
Rated current (Ie): 40 Aac, Input: 0 - 5 / 1 - 5 / 0 - 10 Vdc, External supply: 24 Vdc/Vac, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeProportionalNumber of poles2Rated current AC-5140 AOperating voltage180 V ... 660 VControl
voltage DC0 V ... 10 VAnalogue control signal0-10V, 0-5V, 1-5VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC2P60V40C1DM with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.