

INDUSTRIAL COMPONENT DATA

RGC3P60V30C1DM CARLO GAVAZZI Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 50 AAC RAT..

Brand: CARLO GAVAZZI | Manufacturer Part Number: RGC3P60V30C1DM



Manufacturer	CARLO GAVAZZI
MPN / Reference	RGC3P60V30C1DM
Catalog number	10000
Category	Solid state relay
Minimum order	1 Pcs
Document ID	EO-F18A22B739
Generated	2026-08-05

Product Overview

Selected parameters SYSTEM DIN-rail Mount CURRENT RATING CATEGORY 26 - 50 AAC RATED VOLTAGE 600 VAC OUTPUT SWITCHING MODE Full cycle control NUMBER OF POLES 3 CONTROL DC - ANALOGUE POWER CONNECTION Box Clamp MODEL Proportional Controllers Others CURRENT RATING 30AAC @ 40°C (104°F) integrated heatsink CONTROL INPUT 0...10VDC, 0...5VDC, 1...5VDC, potentiometer PRODUCT WIDTH 70mm

Solid-state relay, three-phase proportional switching controller with integrated heatsink

3-pole DIN-rail mount SSR, Proportional control (1x FC) with monitoring, Operating voltage (Ue): 180 - 660 Vac (1200 Vp), Rated current (Ie): 30 Aac, Input: 0 - 5 / 1 - 5 / 0 - 10 Vdc, External supply: 24 Vdc/Vac, Built-in overvoltage protection

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Switches > Solid state relays
--------------	---

Additional Product Information

Specifications

Output switching modeProportionalNumber of poles3Rated current AC-5130 AOperating voltage180 V ... 660 VControl voltage DC0 V ... 10 VAnalogue control signal0-10V, 0-5V, 1-5VPower connectionBox clamp

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / RGC3P60V30C1DM with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.