

INDUSTRIAL COMPONENT DATA

VN4 CARLO GAVAZZI Selected parameters SYSTEM Sensor HOUSING 1 1/2" pipe thread iso 228/1G SENSING FUNCTION 4..

Brand: CARLO GAVAZZI | Manufacturer Part Number: VN4



Manufacturer	CARLO GAVAZZI
MPN / Reference	VN4
Catalog number	10000
Category	Conductivity sensor
Minimum order	1 Pcs
Document ID	EO-298164F0AE
Generated	2026-08-01

Product Overview

Selected parameters SYSTEM Sensor HOUSING 1 1/2" pipe thread iso 228/1G SENSING FUNCTION 4 Electrodes
MATERIAL Plastic Others SENSING FUNCTION 1 m MATERIAL Nylon 6
Conductive level probe for 4 electrodes without insulation, thread 1 1/2"
Conductive Level Probe, 4 x 1m stainless steel AISI316 dia. 5 mm probes, 2m PVC cable, IP67

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	CARLO GAVAZZI > Sensors > Conductive Level
--------------	--

Additional Product Information

Specifications
Probe length1000 mmMaterial electrodeOtherMax. temperature90 °CType of electric connectionCableSensing
principleConductive
ETIM for VN4 Sensors (EC011624)
Feature Name
Feature Value
Model (EF000010)
Conductive
Insert length (EF020279)
1000 mm

Max. pressure (EF000634)

10 bar

Max. temperature (EF002460)

90 °C

Max. ambient temperature (EF020188)

90 °C

Sensor type (EF020270)

Other

Cell constant (EF012603)

Other

Material electrode (EF012604)

Other

Type of process connection (EF006950)

Other

Material process connection (EF020571)

Other

Type of electric connection (EF003961)

Cable

Elbow plug (EF006417)

No

Cable length (EF000536)

2 m

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send CARLO GAVAZZI / VN4 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.