

INDUSTRIAL COMPONENT DATA

XMW-AC-1-12 171642 Y7-171642 EATON ELECTRIC Auxiliary Contact Set 12P with Labels

Brand: EATON - MOELLER | Manufacturer Part Number: XMW-AC-1-12



Manufacturer	EATON - MOELLER
MPN / Reference	XMW-AC-1-12
Catalog number	Y7-171642
Category	Accessories/spare parts for busbars
Minimum order	1 Pcs
Document ID	EO-0345859E61
Generated	2026-08-05

Product Overview

Auxiliary Contact Set 12P with Labels

XMW-AC-1-12

Eaton xEnergy Main LV switchgear. Auxiliary Contact Set 12P with Labels

MCC individual components: 12-pole auxiliary current contact, terminal labeling on both sides, consisting of: auxiliary current contact socket and plug, weidmüller double-tier terminal 1.5 mm² + blanking plate, cable connection DR. H05V-K YF 0.75 mm² orange, length = 400 mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Enclosures

Additional Product Information

General specifications

Product Name Eaton xEnergy Main LV switchgear Catalog Number 171642 Model Code XMW-AC-1-12 EAN 4015081680023 Product Length/Depth 140 mm Product Height 17 mm Product Width 120 mm Product Weight 0.12 kg

Compliances RoHS conform Product specifications

Accessory/spare part type Other

Accessory

ETIM for 171642 Power distribution systems (EC002270)

Feature Name

Feature Value

Type of accessory/spare part (EF000215)

Other

Accessory (EF013236)

Yes

Spare part (EF013237)

No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / XMW-AC-1-12 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.