

INDUSTRIAL COMPONENT DATA

+NZM3-4-XKCU 266782 Y7-266782 EATON ELECTRIC Box terminal, 4p, bottom up to 630A, size 3. Can only be sold a..

Brand: EATON - MOELLER | Manufacturer Part Number: +NZM3-4-XKCU



Manufacturer	EATON - MOELLER
MPN / Reference	+NZM3-4-XKCU
Catalog number	Y7-266782
Category	Wiring set for power circuit breaker
Minimum order	1 Pcs
Document ID	EO-0817234E6C
Generated	2026-08-05

Product Overview

Box terminal, 4p, bottom up to 630A, size 3. Can only be sold assembled.

+NZM3-4-XKCU

Box terminal, 4p, bottom up to 630A, size 3

Optional accessories for circuit-breaker series NZM offers a comprehensive portfolio of application possibilities for worldwide use. Modular functional groups make mounting flexible and simple. Notes: part no. suffix and part no. contain parts for a circuit-breaker side at top or bottom for 3 or 4 pole circuit-breakers. Conversion kit for circuit-breaker with screw connection. Fitted within the switch housing. O = fitted at the top. U = fitted at the bottom. U e ? 525 VAC. Use NZM3(-4)-XKSA cover. Use ferrules with flexible and highly flexible conductors., observe limited terminal capacity through sleeve . Can be used for: NZM3(-4), PN3(-4), N(N/O)3(-4)

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > Circuit Breakers NZM
--------------	--

Additional Product Information

General specifications

Product Name Eaton Moeller series NZM connection type Catalog Number 266782 Model Code +NZM3-4-XKCU EAN 4015082667825 Product Length/Depth 80 mm Product Height 60 mm Product Width 80 mm Product Weight 0.53 kg

Compliances IEC

RoHS conform Product specifications

Used with NZM3(-4), PN3(-4), N(S)3(-4) Type AccessoryBox terminalTerminal Amperage Rating ? 630 A 10.10

Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation

data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evalu...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / +NZM3-4-XKCU with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.