

INDUSTRIAL COMPONENT DATA

CHM1DNIU EATON ELECTRIC Fused disconnector, low voltage, 30 A, AC 240 V, UL midget, IEC 10 x 38, AC23A, 1P, ..

Brand: EATON - MOELLER | Manufacturer Part Number: CHM1DNIU



Manufacturer	EATON - MOELLER
MPN / Reference	CHM1DNIU
Catalog number	10000
Category	Holder for cylindrical fuse
Minimum order	6 Pcs
Document ID	EO-6D86AF371A
Generated	2026-08-06

Product Overview

1P 10X38MFH30A 600V Midget-indicator

Eaton Bussmann series CHM modular fuse holder, 600V (UL), 690V (IEC), 30A (UL), 32A (IEC), 200 kAIC, Modular fuse holder, Single-pole - CHM1DNIU

MODULAR FUSE HOLDER, MODULAR, INDICATING

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Bussmann Series Low Voltage fuses and accessories

Additional Product Information

General specifications

Product Name Eaton Bussmann series CHM modular fuse holder Catalog Number CHM1DNIU EAN 51712362764 UPC 051712362764 Product Length/Depth 0.001 mm Product Height 0.001 mm Product Width 0.001 mm Product Weight 113 g

Compliances Contact factory

RoHS Compliant Certifications Contact Manufacturer Product specifications

Used with For use with 10 mm X 38 mm fuse Type Modular fuse holder Amperage Rating 30A (UL), 32A (IEC) Number of Poles Single-pole Operating temperature - max 90 °C Operating temperature - min -20 °C Interrupt rating 200 kAIC Wire size #18-4 AWG Voltage rating 600 V (UL), 690 V (IEC)

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / CHM1DNIU with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.