

INDUSTRIAL COMPONENT DATA

CHM1DNU EATON ELECTRIC Fuse-holder, LV, 32 A, AC 690 V, 10 x 38 mm, 1P+N, UL, IEC, DIN rail mount

Brand: EATON - MOELLER | Manufacturer Part Number: CHM1DNU



Manufacturer	EATON - MOELLER
MPN / Reference	CHM1DNU
Catalog number	10000
Category	Holder for cylindrical fuse
Minimum order	6 Pcs
Document ID	EO-4E47757A30
Generated	2026-08-06

Product Overview

1P&Neutral 10X38MFH30A 600V for Midget

Eaton Bussmann series CHM modular fuse holder, 600V (UL), 690V (IEC), 30A (UL), 32A (IEC), 200 kAIC, Modular fuse holder, Single-pole - CHM1DNU

MODULAR FUSE HOLDER, MODULAR, 30A (UL),

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > Bussmann Series Low Voltage fuses and accessories
--------------	---

Additional Product Information

General specifications

Product Name Eaton Bussmann series CHM modular fuse holder Catalog Number CHM1DNU EAN 51712362603 UPC 051712362603 Product Length/Depth 0.001 mm Product Height 0.001 mm Product Width 0.001 mm Product Weight 109.333 g Compliances Contact factory

RoHS Compliant Certifications Contact Manufacturer Product specifications

Used with For use with 10 mm X 38 mm fuse Type Modular fuse holder Amperage Rating 30A (UL), 32A (IEC) Number of Poles Single-pole Operating temperature - max 120 °C Operating temperature - min -20 °C Interrupt rating 200 kAIC Wire size #18-4 AWG Voltage rating 600 V (UL), 690 V (IEC)

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / CHM1DNU with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.