

INDUSTRIAL COMPONENT DATA

DG1-34105FN-C21C 9702-5004-00P Y7-9702-5004-00P EATON ELECTRIC DG1-34105FN-C21C Variable frequency drive, 3-..

Brand: EATON - MOELLER | Manufacturer Part Number: DG1-34105FN-C21C



Manufacturer	EATON - MOELLER
MPN / Reference	DG1-34105FN-C21C
Catalog number	Y7-9702-5004-00P
Category	Frequency converter less than 1 kV
Minimum order	1 Pcs
Document ID	EO-C98E8466C4
Generated	2026-08-05

Product Overview

DG1-34105FN-C21C Variable frequency drive, 3-phase 480 V, 105A, EMC filter, degree of protection IP21

DG1-34105FN-C21C

Variable frequency drive, 400 V AC, 3-phase, 105 A, 55 kW, IP21/NEMA1, DC link choke

Variable frequency drive, Part group reference (e.g. DIL): DG1, Rated operational voltage: Ue = 400 V AC, 3-phase, 480 V AC, 3-phase, 500 V AC, 3-phase, Output voltage with Ve: U2 = 400 V AC, 3-phase, 480 V AC, 3-phase, 500 V AC, 3-phase, Mains voltage (50/60Hz): ULN = 380 (-15%) - 500 (+10%) V, Rated operational current At 150% overload: Ie = 105 A, Note: Rated operational current for a switching frequency of 1 - 10 kHz and an ambient temperature of +50 °C for a 150% overload and +40 °C for a 110% overload, Rated operational current At 110% overload: Ie = 140 A, Note: Overload cycle for 60 s every 600 s , Assigned motor rating Note: for normal internally and externally ventilated 4 pole, three-phase asynchronous motors with 1500 rpm-1 at 50 Hz or 1800 min-1 at 60 Hz, Overload cycle for 60 s every 600 s, at 400 V, 50 Hz, Assigned motor rating 150 % Overload: P = 55 kW, 110 % Overload: P = 75 kW, 150 % Overload: IM = 99 A, 110 % Overload: IM = 134 A, Assigned motor rating Note: at 500 V, 50 Hz, Assigned motor rating 150 % Overload: P = 55 kW, 110 % Overload: P = 90 kW, 150 % Overload: IM = 79 A, 110 % Overload: IM = 129 A, Assigned motor rating Note: at 480 V, 60 Hz, Assigned m...

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **EATON - MOELLER > Power XL Frequency Converters**

Additional Product Information

Variable frequency drive, 400 V AC, 3-phase, 105 A, 55 kW, IP21/NEMA1, DC link chokeVariable frequency drive, Part group reference (e.g. DIL): DG1, Rated operational voltage: Ue = 400 V AC, 3-phase, 480 V AC, 3-phase, 500 V AC,

3-phase, Output voltage with Ve: U2 = 400 V AC, 3-phase, 480 V AC, 3-phase, 500 V AC, 3-phase, Mains voltage (50/60Hz): ULN = 380 (-15%) - 500 (+10%) V, Rated operational current At 150% overload: $I_e = 105$ A, Note: Rated operational current for a switching frequency of 1 - 10 kHz and an ambient temperature of +50 °C for a 150% overload and +40 °C for a 110% overload, Rated operational current At 110% overload: $I_e = 140$ A, Note: Overload cycle for 60 s every 600 s, Assigned motor rating Note: for normal internally and externally ventilated 4 pole, three-phase asynchronous motors with 1500 rpm-1 at 50 Hz or 1800 min-1 at 60 Hz, Overload cycle for 60 s every 600 s, at 400 V, 50 Hz, Assigned motor rating 150 % Overload: $P = 55$ kW, 110 % Overload: $P = 75$ kW, 150 % Overload: $I_M = 99$ A, 110 % Overload: $I_M = 134$ A, Assigned motor rating Note: at 500 V, 50 Hz, Assigned motor rating 150 % Overload: $P = 55$ kW, 110 % Overload: $P = 90$ kW, 150 % Overload: $I_M = 79$ A, 110 % Overload: $I_M = 129$ A, Assigned motor rating Note: at 480 V, 60 Hz, Assigned motor rating 150 % Overload: $P = 75$ HP, 110 % Overload: $P = 100$ HP, Assigned motor rating 150 % Overload: $I_M = 96$ A, 110 % Overload: $I_M = 124$ A, Degree of Protection: IP21/NEMA1, Interface/field bus (built-in): Modbus RT...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / DG1-34105FN-C21C with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.