

INDUSTRIAL COMPONENT DATA

DILA-XHIC11 276527 XTCEXFACC11 EATON ELECTRIC

Auxiliary contact module, 1N/O+1N/C, surface mounting, spring ..

Brand: EATON - MOELLER | Manufacturer Part Number: DILA-XHIC11



Manufacturer	EATON - MOELLER
MPN / Reference	DILA-XHIC11
Catalog number	XTCEXFACC11
Category	Auxiliary contact block
Minimum order	5 Pcs
Document ID	EO-200B1439B1
Generated	2026-08-06

Product Overview

Auxiliary contact module, 1N/O+1N/C, surface mounting, spring clamp connection

Auxiliary Contact Block 1 NO + 1 NC Front Mount Connection To

Auxiliary contact module, 2 pole, Ith= 16 A, 1 N/O, 1 NC, Front fixing, Spring-loaded terminals, DILA, DILM7 - DILM38

Auxiliary contact module, with interlocked opposing contacts, Switching elements according to EN 50005, Version E combinations correspond to EN 50011 and are to be preferred., The DC operated contactor DILA(C)-22 must only be combined with 2-pole auxiliary contacts., Function: for standard applications, 2 pole, Connection technique: Spring-loaded terminals, Rated operational current AC-15 220 V 230 V 240 V: Ie= 4 A, Rated operational current AC-15 380 V 400 V 415 V: Ie= 4 A, Contacts N/O = Normally open: 1 N/O, Contacts N/C = Normally closed: 1 NC, Mounting type: Front fixing, For use with: DILA(C)...., DILM(C)7...., DILM(C)9...., DILM(C)12... , DILM(C)15...., DILM(C)17...., DILM(C)25...., DILM(C)32...., DILM38...., DILMP20...., DILMP32...., DILMP45...., DILL...., DILMF8...., DILMF11...., DILMF14...., DILMF17...., DILMF25...., DILMF32...., Type: Front mounting auxiliary contact, Instructions: Interlocked opposing contacts according to IEC/EN 60947-5-1 appendix L, inside the auxiliary contact modules, also for the integrated auxiliary contacts of the DILM 7 - DILM32, Auxiliary contacts used as mirror contacts according to IEC/EN 60947-4-1 Appendix F (not N/C late open), Code num...

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > KDIL Accessories
--------------	------------------------------------

Additional Product Information

EL-Nummer (Norway)4110268Auxiliary contact module, 2 pole, Ith= 16 A, 1 N/O, 1 NC, Front fixing, Spring-loaded terminals, DILA, DILM7 - DILM38Auxiliary contact module, with interlocked opposing contacts, Switching elements according to EN 50005, Version E combinations correspond to EN 50011 and are to be preferred., The DC operated contactor DILA(C)-22 must only be combined with 2-pole auxiliary contacts., Function: for standard applications, 2 pole, Connection technique: Spring-loaded terminals, Rated operational current AC-15 220 V 230 V 240 V: Ie= 4 A, Rated operational current AC-15 380 V 400 V 415 V: Ie= 4 A, Contacts N/O = Normally open: 1 N/O, Contacts N/C = Normally closed: 1 NC, Mounting type: Front fixing, For use with: DILA(C)..., DILM(C)7..., DILM(C)9..., DILM(C)12..., DILM(C)15..., DILM(C)17..., DILM(C)25..., DILM(C)32..., DILM38..., DILMP20..., DILMP32..., DILMP45..., DILL..., DILMF8..., DILMF11..., DILMF14..., DILMF17..., DILMF25..., DILMF32..., Type: Front mounting auxiliary contact, Instructions: Interlocked opposing contacts according to IEC/EN 60947-5-1 appendix L, inside the auxiliary contact modules, also for the integrated auxiliary contacts of the DILM 7 - DILM32, Auxiliary contacts used as mirror contacts according to IEC/EN 60947-4-1 Appendix F (not N/C late open), Code number and version of combination Distinctive number: 51E, 42, 33Delivery program

AccessoriesAuxiliary contact modulesDescriptionwith interlocked opposing contacts

Switching elements according to EN 50005

Version E combin...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / DILA-XHIC11 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.