

INDUSTRIAL COMPONENT DATA

DILEM-01(600V60HZ) 010327 XTMC9A01K6 EATON ELECTRIC Contactor, 3-pole + 1 N/C, 4 kW/400 V/AC3

Brand: EATON - MOELLER | Manufacturer Part Number: DILEM-01(600V60HZ)



Manufacturer	EATON - MOELLER
MPN / Reference	DILEM-01(600V60HZ)
Catalog number	XTMC9A01K6
Category	Power contactor, AC switching
Minimum order	1 Pcs
Document ID	EO-A9582E44EA
Generated	2026-08-06

Product Overview

Contactor, 3-pole + 1 N/C, 4 kW/400 V/AC3

Mini-power Contactor; Connection screw; 3-pole + 1 NC; 9; 4 kW; 400 V; AC-3; 600 V 60 Hz

Contactor, 600 V 60 Hz, 3 pole, 380 V 400 V, 4 kW, Contacts N/C = Normally closed= 1 NC, Screw terminals, AC operation

Contactor, DILEM contactors, Utilization category: AC-1: Non-inductive or slightly inductive loads, resistance furnaces, NAC-3: Normal AC induction motors: starting, switch off during running, AC-4: Normal AC induction motors: starting, plugging, reversing, inching, Connection technique: Screw terminals, Notes: Also suitable for motors with efficiency class IE3., IE3-ready devices are identified by the logo on their packaging., Description: With auxiliary contact, Number of poles: 3 pole, Rated operational current AC-3 380 V 400 V: I_e= 9 A, Rated operational current AC-1 Conventional free air thermal current, 3 pole , 50 - 60 Hz Open at 40 °C: I_{th} =I_e= 22 A, enclosed: I_{th}= 16 A, Rated operational current AC-1 Conventional free air thermal current, 1 pole open: I_{th}= 50 A, enclosed: I_{th}= 40 A, Max. rating for three-phase motors, 50 - 60 Hz AC-3 220 V 230 V: P= 2.2 kW, 380 V 400 V: P= 4 kW, 660 V 690 V: P= 4 kW, Max. rating for three-phase motors, 50 - 60 Hz AC-4 220 V 230 V: P= 1.5 kW, 380 V 400 V: P= 3 kW, 660 V 690 V: P= 3 kW, For use with: ...DILE, Contacts N/C = Normally closed: 1 NC, Voltage AC/DC: AC operation

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Contactors up to 170A

Additional Product Information

Contactor, 600 V 60 Hz, 3 pole, 380 V 400 V, 4 kW, Contacts N/C = Normally closed= 1 NC, Screw terminals, AC operation
Contactor, DILEM contactors, Utilization category: AC-1: Non-inductive or slightly inductive loads, resistance furnaces, NAC-3: Normal AC induction motors: starting, switch off during running, AC-4: Normal AC induction motors:

starting, plugging, reversing, inching, Connection technique: Screw terminals, Notes: Also suitable for motors with efficiency class IE3., IE3-ready devices are identified by the logo on their packaging., Description: With auxiliary contact, Number of poles: 3 pole, Rated operational current AC-3 380 V 400 V: $I_e = 9$ A, Rated operational current AC-1 Conventional free air thermal current, 3 pole, 50 - 60 Hz Open at 40 °C: $I_{th} = I_e = 22$ A, enclosed: $I_{th} = 16$ A, Rated operational current AC-1 Conventional free air thermal current, 1 pole open: $I_{th} = 50$ A, enclosed: $I_{th} = 40$ A, Max. rating for three-phase motors, 50 - 60 Hz AC-3 220 V 230 V: $P = 2.2$ kW, 380 V 400 V: $P = 4$ kW, 660 V 690 V: $P = 4$ kW, Max. rating for three-phase motors, 50 - 60 Hz AC-4 220 V 230 V: $P = 1.5$ kW, 380 V 400 V: $P = 3$ kW, 660 V 690 V: $P = 3$ kW, For use with: ...DILE, Contacts N/C = Normally closed: 1 NC, Voltage AC/DC: AC operation Delivery program

Product range Contactors Subrange DILEM contactors Utilization category AC-1: Non-inductive or slightly inductive loads, resistance furnaces

NAC-3: Normal AC induction motors: starting, switch off during running

AC-4: Normal AC induction mot...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / DILEM-01(600V60HZ) with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.