

INDUSTRIAL COMPONENT DATA

DXG-NET-PROFIBUS 744-A2617-00P Y7-744-A2617-00P

EATON ELECTRIC ProfibusDP field bus module for DG1 variable ..

Brand: EATON - MOELLER | Manufacturer Part Number: DXG-NET-PROFIBUS



Manufacturer	EATON - MOELLER
MPN / Reference	DXG-NET-PROFIBUS
Catalog number	Y7-744-A2617-00P
Category	Accessories/spare parts for frequency controller
Minimum order	1 Pcs
Document ID	EO-E08EA4546A
Generated	2026-08-04

Product Overview

ProfibusDP field bus module for DG1 variable frequency drive

DXG-NET-PROFIBUS

Field bus module, Bus protocol: PROFIBUS-DP, Description: SUB-D socket, 9-pole, For use with: DG1

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **EATON - MOELLER > Power XL Frequency Converters**

Additional Product Information

General specifications

Product Name Eaton DXG Communication module Catalog Number 744-A2617-00P Model Code DXG-NET-PROFIBUS
EAN 4015081721955 Product Length/Depth 45 mm Product Height 130 mm Product Width 105 mm Product Weight 0.023
kg Compliances CE Certifications UL File No.: E134360
UL Category Control No.: NMMS, NMMS7
UL 508C
CSA-C22.2 No. 14
IEC/EN61800-3
IEC/EN61800-5
CE marking
UL Listed

UL report applies to both US and Canada Catalog Notes SUB-D socket, 9-pole Product specifications

Used with DG1 Product Category Accessories 10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resi...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / DXG-NET-PROFIBUS with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.