

INDUSTRIAL COMPONENT DATA

Low Voltage North American CGL-3 EATON ELECTRIC Fuse-link, low voltage, 3 A, AC 600 V, DC 250 V, HRCII-C, 24..

Brand: EATON - MOELLER | Manufacturer Part Number: Low Voltage - North American



Manufacturer	EATON - MOELLER
MPN / Reference	Low Voltage - North American
Catalog number	CGL-3
Category	Low Voltage HRC fuse
Minimum order	1 Pcs
Document ID	EO-15F413525B
Generated	2026-08-06

Product Overview

Fuse-link, low voltage, 3 A, AC 600 V, DC 250 V, HRCII-C, 24 x 84 mm, CSA
LIMITRON FAST ACTING FUSE

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > Bussmann fuses
--------------	----------------------------------

Additional Product Information

Fuse-link, low voltage, 3 A, AC 600 V, DC 250 V, HRCII-C, 24 x 84 mm, CSA Fuse, Fuse-link, low voltage, 3 A, AC 600 V, DC 250 V, HRCII-C, 24 x 84 mm, CSA, offset bolted tags (slotted), motor protection, Breaking Capacity 200 kA Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Low Voltage HRC fuse (EC000055) Electric engineering, automation, process control engineering / Electrical installation, device / Safety fuse inserts / Low-Voltage HRC fuse () [AFZ800015]) Construction size Other Rated current 3 A Rated voltage 600 V Voltage type AC Rated switching capacity 80 kA Utilization category Other Type of fuse status indicator None Insulated metal gripping lugs (IMGL) No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / Low Voltage - North American with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.