

UL/CSA

RoHS conform Certifications UL489

CSA certified

CSA (Class No. 1437-01)

UL (Category Control Number DIHS)

UL listed

CSA-C22.2 No. 5-09

IEC60947

CSA (File No. 22086)

UL (File No. E140305)

CE marking Product specifications

Used with PXR20(25) NZM4(-4)-...X... Type Accessory Undervoltage release Undervoltage release with two relays Special features Instantaneous shut-off of the NZM circuit breaker when control voltage drops below 35 - 70% Us For use with emergency-stop devices and an emergency-stop button For signaling commands or different states of the circuit-breaker Two relays per unit Actuation reason can be configured in the trip unit Configuration via communication or circuit breaker display or front USB connection and Eaton Power Xpert Protection Manager When the under-voltage trip is switched off, accidental contact with the circuit breaker's primary contacts is prevented when switched on Only for use in combination with circuit-breakers with electronic trips Undervoltage release modules cannot be installed with early-make contact NZM...-XHIV, shunt release NZM...-XA... or relais modules NZM...-X2A.. Relay coil is controlled by trip unit Push-in relay contact for control wiring Relays can be used for controlling remote operator with Us=20...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / NZM4-XU2A110-130AC with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten PI #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.