

INDUSTRIAL COMPONENT DATA

OPTE9 197872 Y7-197872 EATON ELECTRIC Field bus module

Brand: EATON - MOELLER | Manufacturer Part Number: OPTE9



Manufacturer	EATON - MOELLER
MPN / Reference	OPTE9
Catalog number	Y7-197872
Category	Accessories/spare parts for frequency controller
Minimum order	1 Pcs
Document ID	EO-4EE29A63E3
Generated	2026-08-03

Product Overview

Field bus module
Ethernet option board for SVX/SPX

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **EATON - MOELLER > Power XL Frequency Converters**

Additional Product Information

Field bus moduleDelivery program
Bus protocolModbus TCP
Profinet IO
EtherNet-IPDescriptionThe field bus module is plugged into the variable-frequency drive.For use withSVX, SPXConnection technique2 x RJ45, 8 poleApprovals
Product StandardsUL 508C; CSA-C22.2 No. 14; IEC/EN61800-3; IEC/EN61800-5; CE markingUL File No.E134360UL
Category Control No.NMMS, NMMS2, NMMS7. NMMS8CSA File No.UL report applies to both US and CanadaNorth America CertificationUL listed, certified by UL for use in CanadaSpecially designed for North AmericaNoSuitable forBranch circuits
ETIM for 197872 Low-voltage industrial controls and switchgear (EC002025)
Feature Name
Feature Value
Type of accessory/spare part (EF000215)
Communication module
Accessory (EF013236)

Yes

Spare part (EF013237)

No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / OPTE9 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.