

INDUSTRIAL COMPONENT DATA

T0-5-8369/E 060204 Y7-60204 EATON ELECTRIC

Changeoverswitches, Contacts: 10, 20 A, front plate: 1-2, 90 °, m..

Brand: EATON - MOELLER | Manufacturer Part Number: T0-5-8369/E



Manufacturer	EATON - MOELLER
MPN / Reference	T0-5-8369/E
Catalog number	Y7-60204
Category	Off-load switch
Minimum order	1 Pcs
Document ID	EO-4CD74495E7
Generated	2026-08-01

Product Overview

Changeoverswitches, Contacts: 10, 20 A, front plate: 1-2, 90 °, maintained, flush mounting

Switch Switch. 10 poles. 20 A. Indicator plate: 1-2. 90 °.

Eaton Moeller® series T0 Changeoverswitches, T0, 20 A, flush mounting, 5 contact unit(s), Contacts: 10, 90 °, maintained, Without 0 (Off) position, 1-2, Design number 8369

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Disconnectors and Cam Switches

Additional Product Information

General specifications

Product Name Eaton Moeller® series T0 Changeover switch Catalog Number 060204 Model Code T0-5-8369/E EAN 4015080602040 Product Length/Depth 114 mm Product Height 48 mm Product Width 48 mm Product Weight 0.147 kg Certifications CSA-C22.2 No. 60947-4-1-14

UL 60947-4-1

VDE 0660

IEC/EN 60204

UL

CSA-C22.2 No. 94

IEC/EN 60947-3

CSA File No.: 012528

CSA Class No.: 3211-05

IEC/EN 60947

UL Category Control No.: NLRV

UL File No.: E36332

CSA

CE Catalog Notes Rated Short-time Withstand Current (Icw) for a time of 1 second

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / T0-5-8369/E with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.