

INDUSTRIAL COMPONENT DATA

PKE-XTU-65 138259 Y7-138259 EATON ELECTRIC Trip block, 16-65A, standard

Brand: EATON - MOELLER | Manufacturer Part Number: PKE-XTU-65



Manufacturer	EATON - MOELLER
MPN / Reference	PKE-XTU-65
Catalog number	Y7-138259
Category	Tripping bloc for power circuit-breaker
Minimum order	1 Pcs
Document ID	EO-B0D945C792
Generated	2026-08-03

Product Overview

Trip block, 16-65A, standard

PKE-XTU-65

Eaton Moeller® series PKE Trip block, 16 - 65 A, Motor protection, Connection to SmartWire-DT: no, For use with: PKE65 basic device

Electronic control unit for motor protection according to IEC60947-4-1 for basic device PKE65, electronic wide-range overload protection (4:1), phase-failure and unbalance protection, adjustable tripping class. ATEX accreditation

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > Electronic Circuit Breakers
--------------	---

Additional Product Information

General specifications

Product Name Eaton Moeller® series PKE Trip block Catalog Number 138259 Model Code PKE-XTU-65 EAN

4015081350391 Product Length/Depth 84.4 mm Product Height 69.9 mm Product Width 55 mm Product Weight 0.238 kg

Certifications UL

VDE 0660

CSA Class No.: 3211-05

IEC/EN 60947

IEC/EN 60947-4-1

UL Category Control No.: NLRV

CSA-C22.2 No. 14-10

UL 508

UL File No.: E36332

CSA

CSA File No.: 165628

CE Catalog Notes This is a product for Environment A (Industrial). In environment B (household) this device may cause undesirable radio interference. In this case the user may be obliged to take appropriate measures. Features & Functions

Features Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102) Functions Motor protection for heavy starting duty

Overload release

Motor protection Number of poles Three-pole General

Current flow times - min 500 (Class 5) AC-4 cycle operation, Main conducting paths

900 (Class 15) AC-4 cycle operation, Main conducting paths

1000 (Class 20) AC-4 cycle operation, Main conducting paths

Note: Going below the minimum current flow time can cause overheating of the load (motor).

For all combinations with an SWD activation, you need not adhere to the minimum current flow times and minimum cut-out periods.

700 (Class 10) AC-4 cycle operation, Main conducting paths Cut-out periods - min ≤ 500 ms, main conducting paths, AC-4 cycle operation Degree of protection Device: IP20

Terminals: IP00 Operating frequency 60 Operations/h....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / PKE-XTU-65 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.