

INDUSTRIAL COMPONENT DATA

PKE-XTUA-32 121730 Y7-121730 EATON ELECTRIC Trip block, 8-32A, networkable, motor protection

Brand: EATON - MOELLER | Manufacturer Part Number: PKE-XTUA-32



Manufacturer	EATON - MOELLER
MPN / Reference	PKE-XTUA-32
Catalog number	Y7-121730
Category	Tripping bloc for power circuit-breaker
Minimum order	1 Pcs
Document ID	EO-D2BF787C40
Generated	2026-08-04

Product Overview

Trip block, 8-32A, networkable, motor protection

PKE-XTUA-32

Eaton Moeller® series PKE Trip block, 8 - 32 A, Motor protection, Connection to SmartWire-DT: yes, For use with: PKE32 basic device

Electronic control unit for motor protection according to IEC60947-4-1 for basic device PKE32, electronic wide-range overload protection (4:1), phase-failure and unbalance protection, adjustable tripping class. Device for world markets, ATEX accreditation

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Electronic Circuit Breakers

Additional Product Information

General specifications

Product Name Eaton Moeller® series PKE Trip block Catalog Number 121730 Model Code PKE-XTUA-32 EAN 4015081195404 Product Length/Depth 41.6 mm Product Height 64.2 mm Product Width 45 mm Product Weight 0.09 kg

Certifications CSA File No.: 165628

UL Category Control No.: NLRV

UL File No.: E36332

IEC/EN 60947-4-1

UL 508

CSA

CSA Class No.: 3211-05

VDE 0660

IEC/EN 60947

UL

CSA-C22.2 No. 14-10

CE Catalog Notes This is a product for Environment A (Industrial). In environment B (household) this device may cause undesirable radio interference. In this case the user may be obliged to take appropriate measures. Features & Functions

Features Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102) Functions Overload release

Motor protection

Motor protection for heavy starting duty Number of poles Three-pole General

Current flow times - min Note: Going below the minimum current flow time can cause overheating of the load (motor).

900 (Class 15) AC-4 cycle operation, Main conducting paths

For all combinations with an SWD activation, you need not adhere to the minimum current flow times and minimum cut-out periods.

500 (Class 5) AC-4 cycle operation, Main conducting paths

1000 (Class 20) AC-4 cycle operation, Main conducting paths

700 (Class 10) AC-4 cycle operation, Main conducting paths Cut-out periods - min $\leq$ 500 ms, main conducting paths, AC-4 cycle operation Degree of protection Device: IP20

Terminals: IP00 Operating frequency 60 Operations/h....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / PKE-XTUA-32 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.