

INDUSTRIAL COMPONENT DATA

PKE-XTUW-32 138261 Y7-138261 EATON ELECTRIC Trip block, 8-32A, standard

Brand: EATON - MOELLER | Manufacturer Part Number: PKE-XTUW-32



Manufacturer	EATON - MOELLER
MPN / Reference	PKE-XTUW-32
Catalog number	Y7-138261
Category	Tripping bloc for power circuit-breaker
Minimum order	1 Pcs
Document ID	EO-3F1B0D6392
Generated	2026-08-03

Product Overview

Trip block, 8-32A, standard

PKE-XTUW-32

Eaton Moeller® series PKE Trip block, 8 - 32 A, Motor protection, Connection to SmartWire-DT: no, For use with: PKE65 basic device

Electronic control unit for motor protection according to IEC60947-4-1 for basic device PKE65., electronic wide-range overload protection (4:1), phase-failure and unbalance protection, adjustable tripping class. ATEX accreditation

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path EATON - MOELLER > Electronic Circuit Breakers

Additional Product Information

General specifications

Product Name Eaton Moeller® series PKE Trip block Catalog Number 138261 Model Code PKE-XTUW-32 EAN

4015081350414 Product Length/Depth 84.4 mm Product Height 69.9 mm Product Width 55 mm Product Weight 0.196 kg

Certifications CSA-C22.2 No. 14-10

VDE 0660

UL

CSA File No.: 165628

CE

IEC/EN 60947

IEC/EN 60947-4-1

CSA Class No.: 3211-05

CSA

UL 508

UL File No.: E36332

UL Category Control No.: NLRV Catalog Notes This is a product for Environment A (Industrial). In environment B (household) this device may cause undesirable radio interference. In this case the user may be obliged to take appropriate measures. Features & Functions

Features Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102) Functions Motor protection
Overload release

Motor protection for heavy starting duty Number of poles Three-pole General

Current flow times - min 500 (Class 5) AC-4 cycle operation, Main conducting paths

700 (Class 10) AC-4 cycle operation, Main conducting paths

1000 (Class 20) AC-4 cycle operation, Main conducting paths

Note: Going below the minimum current flow time can cause overheating of the load (motor).

900 (Class 15) AC-4 cycle operation, Main conducting paths

For all combinations with an SWD activation, you need not adhere to the minimum current flow times and minimum cut-out periods. Cut-out periods - min ≤ 500 ms, main conducting paths, AC-4 cycle operation Degree of protection Device: IP20

Terminals: IP00 Operating frequency 60 Operations/h...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / PKE-XTUW-32 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.