

INDUSTRIAL COMPONENT DATA

XPNW-R-BCB-2-1008 178643 Y7-178643 EATON ELECTRIC Partition NZM4 withdrawable unit with remote operator cabl..

Brand: EATON - MOELLER | Manufacturer Part Number: XPNW-R-BCB-2-1008



Manufacturer	EATON - MOELLER
MPN / Reference	XPNW-R-BCB-2-1008
Catalog number	Y7-178643
Category	Divider panel (switchgear cabinet)
Minimum order	1 Pcs
Document ID	EO-C53862F2DF
Generated	2026-08-04

Product Overview

Partition; NZM4; withdrawable unit with remote operator; cable connection area/busbar area; WxD=1000x800mm

XPNW-R-BCB-2-1008

Eaton xEnergy Main LV systems LV switchgear. Partition, NZM4, withdrawable unit with remote operator, cable connection area/busbar area, WxD=1000x800mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	EATON - MOELLER > Enclosures
--------------	------------------------------

Additional Product Information

General specifications

Product Name Eaton xEnergy Main LV switchgear Catalog Number 178643 Model Code XPNW-R-BCB-2-1008 EAN 4015081739721 Product Length/Depth 391 mm Product Height 43.2 mm Product Width 989 mm Product Weight 2.5 kg

Compliances RoHS conform Product specifications

Construction type Individual part Fitted with: Lock Surface finishing Galvanized Color Stainless steel Modular spacing 12.5 mm Number of height units 0 RAL-number 0 Suitable for enclosure building length/depth 800 mm Suitable for enclosure building width 1000 mm Material Steel Suitable for Internal separation form 4b

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send EATON - MOELLER / XPNW-R-BCB-2-1008 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.