

INDUSTRIAL COMPONENT DATA

52000350 SKINDICHT SVRE PG 29 LAPP SKINDICHT SVRE PG 29

Brand: LAPP | Manufacturer Part Number: 52000350



Manufacturer	LAPP
MPN / Reference	52000350
Catalog number	SKINDICHT SVRE PG 29
Category	Cable gland
Minimum order	50 Pcs
Document ID	EO-F07FCB2524
Generated	2026-08-02

Product Overview

SKINDICHT SVRE PG 29

SKINDICHT® SVRE

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LAPP > SKINDICHT cabling
--------------	--------------------------

Additional Product Information

SKINDICHT® SVRE, PG cable gland with incised sealing ring and hexagonal fitting

Benefits

With incised sealing ring for adjustment to several cable diameters

Fewer sizes need to be kept in stock

Application range

Brass cable gland with hexagonal fitting and variable incised sealing ring.

Product Make-up

PG connection thread

Note

Refer to SKINDICHT® EV for additional accessories

Counter nut to be used: SKINDICHT® SM

Classification ETIM 5

ETIM 5.0 Class-ID: EC000441

ETIM 5.0 Class-Description: Cable screw gland

Classification ETIM 6

ETIM 6.0 Class-ID: EC000441

ETIM 6.0 Class-Description: Cable screw gland

Caution

The installation dimensions
can be found in appendix T21

On request

Available with long connection thread

Available with PG 11 to 36 with FKM incised ring

Material

Body: nickel-plated brass

Incised seal: CR

Protection rating

IP 54

Temperature range

-20°C to +80°C

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LAPP / 52000350 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.