

INDUSTRIAL COMPONENT DATA

53119250 SKINTOP GMP-HF-M 40x1,5 RAL7035 LGY LAPP SKINTOP GMP-HF-M 40x1,5 RAL7035 LGY

Brand: LAPP | Manufacturer Part Number: 53119250



Manufacturer	LAPP
MPN / Reference	53119250
Catalog number	SKINTOP GMP-HF-M 40x1,5 RAL7035 LGY
Category	Cable gland
Minimum order	25 Pcs
Document ID	EO-873693592F
Generated	2026-08-06

Product Overview

SKINTOP GMP-HF-M 40x1,5 RAL7035 LGY

SKINTOP® GMP-HF-M

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LAPP > SKINTOP cabling

Additional Product Information

SKINTOP® GMP-HF-M, halogen-free counter nuts, extremely flame-retardant, self-extinguishing, no dripping, for public buildings

Benefits

Halogen-free

Extremely flame-retardant according to UL 94 V0

Self-extinguishing, no dripping

Application range

Airports

Tunnel construction

Underground railways

Public buildings

Product Make-up

Metric connection thread acc. to DIN EN 60423

Basis for technical information DIN IEC 62444

Note

Designed for use with SKINTOP® ST-HF-M

Classification ETIM 5

ETIM 5.0 Class-ID: EC000940

ETIM 5.0 Class-Description: Locknut for cable screw gland

Classification ETIM 6

ETIM 6.0 Class-ID: EC000940

ETIM 6.0 Class-Description: Locknut for cable screw gland

Colour delivered

Light grey (RAL 7035)

Black (RAL 9005), UV-resistant

Material

halogenfree polyamide acc. to UL 94 V0

Temperature range

Fixed: -40°C to +100°C

Dynamic: -20°C to +100°C

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LAPP / 53119250 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.