

INDUSTRIAL COMPONENT DATA

61721990 AHI L 16/18 GN LAPP END SLEEVES AHI L 16/18 GN

Brand: LAPP | Manufacturer Part Number: 61721990



Manufacturer	LAPP
MPN / Reference	61721990
Catalog number	AHI L 16/18 GN
Category	Cable end sleeve
Minimum order	100 Pcs
Document ID	EO-B0233335DD
Generated	2026-08-04

Product Overview

END SLEEVES AHI L 16/18 GN
Conductor end sleeves insulated

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LAPP > Connection engineering

Additional Product Information

Conductor end sleeves with insulation for cabinet builders , according to DIN or German colour code, halogen-free
Now with UL approval

Benefits

Funnel-shaped opening makes it easy to slip them onto the strands

The conductor is permanently connected to the collar by crimping

Application range

Control cabinets and equipment wiring

For cables with category 2,5 and 6 conductors

Not suitable for solid conductors

Norm references / Approvals

All DIN conductor end-sleeves are in accordance with DIN 46228 Part 4

UL File No. E507990, see table

Fire behaviour according to UL 94 HB

Note

From 16mm sleeve length (l2) 2x crimp

Classification ETIM 5

ETIM 5.0 Class-ID: EC000005

ETIM 5.0 Class-Description: Cable end sleeve

Classification ETIM 6

ETIM 6.0 Class-ID: EC000005

ETIM 6.0 Class-Description: Cable end sleeve

Note

Halogen-free

Material

Copper/PP

Surface: tin-plated

Temperature range

-5°C to +105°C

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LAPP / 61721990 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.