

INDUSTRIAL COMPONENT DATA

63204475 KB50-12R DIN 46234 LAPP CABLE LUGS KB50-12R DIN 46234

Brand: LAPP | Manufacturer Part Number: 63204475



Manufacturer	LAPP
MPN / Reference	63204475
Catalog number	KB50-12R DIN 46234
Category	Solderless copper terminals for copper conductors
Minimum order	100 Pcs
Document ID	EO-53A87ED3E1
Generated	2026-08-01

Product Overview

CABLE LUGS KB50-12R DIN 46234

Solderless cable lugs KB

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LAPP > Connection engineering

Additional Product Information

Uninsulated cable lugs/solderless terminals according to DIN 46234, high-quality electrolytic copper for good conductivity, least resistance

Benefits

For first-class connection with simple operating principle

Thus providing the best electrical conductivity (least resistance)

Application range

For cables with category 2,5 and 6 conductors

Manufacturing of control cabinets and equipment

Trains and buses

Norm references / Approvals

In accordance with VG 88710

Coil form DIN 46234 (versions mit * are not according to DIN 46234)

Classification ETIM 5

ETIM 5.0 Class-ID: EC001052

ETIM 5.0 Class-Description: Solderless copper terminals for copper conductors

Classification ETIM 6

ETIM 6.0 Class-ID: EC001052

ETIM 6.0 Class-Description: Solderless copper terminals for copper conductors

Note

s = thickness of material

Material

High-quality electrolytic copper for good conductivity

Temperature range

Temperature range up to +120°C

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LAPP / 63204475 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.