


INDUSTRIAL COMPONENT DATA

004653 LEGRAND SWITCH VOLTIMETRO 7 POS

Brand: LEGRAND | Manufacturer Part Number: 004653



Manufacturer	LEGRAND
MPN / Reference	004653
Catalog number	004653
Category	Voltmeter selector switch
Minimum order	1 Pcs
Document ID	EO-12A88BCC09
Generated	2026-08-01

Product Overview

SWITCH VOLTIMETRO 7 POS

Voltmeter cam switch Lexic- 3-phase+neutral - 7 positions -3 modules -fixing on rail

Voltmeter rotary switch - 7 positions

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LEGRAND > SUPERVISION AND ENERGY MEASUREMENT

Additional Product Information

Pack (number of units)1

Volume (dm3)0.521

Weight (g)150.00

Product characteristicsSelective measurement switches

For manual selection of the circuits to be measured

Voltmeter cam switches

For measuring the voltages in a circuit with one voltmeter

3-phase with neutral,

7-position cam switch

Number of modules : 3

General characteristicsElectrical energy metering on rail

ETIM for 004653 Low-voltage industrial controls and switchgear (EC000911)

Feature Name

Feature Value

Degree of protection (IP) (EF005474)

IP40

Measurement between phases possible (EF001145)

Yes

Measurement between phase and neutral conductor possible (EF001144)

Yes

Modular version (EF001126)

Yes

With control element (EF001538)

No

With zero (off) position (EF001416)

Yes

Device construction (EF008240)

Surface mounting

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 004653 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.