

INDUSTRIAL COMPONENT DATA

012006 LEGRAND FUSE CYLINDRICAL /00/6

Brand: LEGRAND | Manufacturer Part Number: 012006



Manufacturer	LEGRAND
MPN / Reference	012006
Catalog number	012006
Category	Cylindrical fuse
Minimum order	10 Pcs
Document ID	EO-0BEAC94BA4
Generated	2026-07-31

Product Overview

FUSE CYLINDRICAL /00/6

Legrand 6A Type aM Cylindrical Cartridge Fuse without Indicator 8mm x 32mm

Cylindrical fuse cartridge - aM - 8.5x32 - without indicator - 6A

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LEGRAND > ACCESSORIES CONTROL AND CONTROL PANELS

Additional Product Information

Cylindrical type aM (motor rated) Conform to BS EN 60269-1 (BS 88) IEC 60269-1 Bureau Veritas approved Model Ceramic fuse

Size 8x32 mm

Rated current 6 A

Depth 31.5 mm

Width 8.5 mm

Voltage type AC/DC

Utilization category according to IEC 60269 AM

Rated operating frequency 42-62 Hz

Type of fuse status indicator Other

Power loss at rated current 0.83 W

Operating / setting temperature -25-40 °C

Storage temperature -40-70 °C

ETIM for 012006 Circuit breakers and fuses (EC002704)

Feature Name

Feature Value

Utilization category according to IEC 60269 (EF002572)

aM (switchgear protection)

Model (EF000010)

Ceramic fuse

Type of fuse status indicator (EF004473)

Other

Voltage type (EF000187)

AC/DC

Size (EF000088)

8x32mm

Power loss at rated current (EF012389)

0.83 W

Rated current (EF000227)

6 A

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 012006 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.