

INDUSTRIAL COMPONENT DATA

020446 LEGRAND XL3 800 CAP C/L INTERNAL 1000H

Brand: LEGRAND | Manufacturer Part Number: 020446



Manufacturer	LEGRAND
MPN / Reference	020446
Catalog number	020446
Category	Front plate (switchgear cabinet)
Minimum order	1 Pcs
Document ID	EO-E45AADD852
Generated	2026-07-29

Product Overview

XL3 800 CAP C/L INTERNAL 1000H

Cover cubrebornas blind hinge and lock XL3 800-for cell lateral internal

Blind terminal cover hinge and lock XL³ 800 for internal side cell

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND > XL3 800-4000 ENERGY DISTRIBUTION CABINETS
--------------	---

Additional Product Information

Product features

Cells lateral internal Caps cubrebornas with hinges and locks - To-cell lateral internal height 1050 or 1095 mm General characteristics

XL3 800 - cabinets IP 55 - IP 55 with door IK 08 - Cell metal - Suitable for devices up to 630 A - fire Resistance according to IEC 60695-2-11: 750 °C/5 sec - Capacity 24 and 36 modules per row - RAL 7035 (socket RAL 7004) - Coupling horizontal - To outside industrial and urban sheltered

ETIM for 020446 Cabinets and enclosures (EC000456)

Feature Name

Feature Value

Height (EF000040)

1000 mm

Material (EF002169)

Steel

Surface finishing (EF006569)

Powder coated

Suitable for enclosure building width (EF000326)

460 mm

Width (EF000008)

250 mm

Suitable for enclosure building height (EF009583)

1095 mm

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 020446 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.