

INDUSTRIAL COMPONENT DATA

020585 LEGRAND XL3 KIT SEALING TO IP55

Brand: LEGRAND | Manufacturer Part Number: 020585



Manufacturer	LEGRAND
MPN / Reference	020585
Catalog number	020585
Category	Component for door (switchgear cabinet)
Minimum order	1 Pcs
Document ID	EO-7824D8FD57
Generated	2026-08-03

Product Overview

XL3 KIT SEALING TO IP55

Sealing kit - for use when joining XL³ 800/4000 IP55 cabinets together

IP55 XL³ 800/4000 sealing kit

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LEGRAND > XL3 800-4000 ENERGY DISTRIBUTION CABINETS

Additional Product Information

Pack (number of units)1

Volume (dm3)1.322

Weight (g)282.00

Product characteristicsMounting equipment

Joining

Sealing kit IP 55 for use when joining cabinets - length 5 m

General characteristicsDistribution enclosures XL³ 4000IP 30 - IK 07

IP 55 - IK 08 with door and sealing kit for use when joining enclosures

Consist of the combination of a "roof-base" assembly, structural uprights, functional uprights, rear and side panels RAL 7035, plinths RAL 7004

Height 2000 or 2200 mm.

Capacity 24 modules (enclosures width 725 or width 975 with internal cable sleeve), 36 modules (enclosures width 975)

Usable faceplate height 1800 mm (1700 mm only if using the pivoting support frame) or 2000 mm

ETIM for 020585 Cabinets and enclosures (EC002626)

Feature Name

Feature Value

Model (EF000010)

Other

Material (EF002169)

Plastic

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 020585 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.