

INDUSTRIAL COMPONENT DATA**021533 LEGRAND BCC BREAKER SECC/T1/1P**

Brand: LEGRAND | Manufacturer Part Number: 021533



Manufacturer	LEGRAND
MPN / Reference	021533
Catalog number	021533
Category	Holder for cylindrical fuse
Minimum order	1 Pcs
Document ID	EO-97FE5BFC55
Generated	2026-07-31

Product Overview

BCC BREAKER SECC/T1/1P

Circuit breaker seccionable - SP 51 - 1P - cartridge fuse-14x51 - micro nc

Sectional circuit breaker - SP 51 - 1P - fuse cartridge 14x51 - micro breaker

STRUCTURED PRODUCT DATA**Technical Specifications**

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog PathCatalog path **LEGRAND > MOTOR CIRCUIT BREAKERS****Additional Product Information**

Product features

SP 51 for cartridge fuse 14 x 51 - Connection 1 x 35 or 2 x 16 mm² - 1P - Presence and fusion of the cartridge fuse, pre-cut and DPMM (device of protection against the fly in single phase) - With microinterruptor: - Number of modules: 1,5 General characteristics

Circuit breaker seccionables SP - with terminals protected - Conform to standard IEC 60269-2 - Approved by Bureau Veritas - Height under lid cubrebornas 44 mm - screw Heads-track joint to facilitate the tightening of the cable - Fixation with screw or rail symmetrical

ETIM for 021533 Circuit breakers and fuses (EC002705)

Feature Name

Feature Value

For fuse size (EF008316)

14x51 mm

Degree of protection (IP) (EF005474)

IP20

Concurrently switching neutral conductor (EF005997)

No

Mounting method (EF000003)

DIN rail

Nominal voltage (EF000002)

400 V

Number of poles (EF001391)

1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 021533 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.