

INDUSTRIAL COMPONENT DATA

021601 LEGRAND BCC BREAKER SECC/T2/1P

Brand: LEGRAND | Manufacturer Part Number: 021601



Manufacturer	LEGRAND
MPN / Reference	021601
Catalog number	021601
Category	Holder for cylindrical fuse
Minimum order	3 Pcs
Document ID	EO-6761A8FB53
Generated	2026-07-31

Product Overview

BCC BREAKER SECC/T2/1P

Legrand SP 58 Isolating Fuse Carrier with Protected Terminals 22mm x 58mm 1 Pole

Sectional circuit breaker - SP 58 - 1P - fuse cartridge 22x58

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	LEGRAND > MOTOR CIRCUIT BREAKERS
--------------	----------------------------------

Additional Product Information

SP fuse carriers Conform to IEC 60269-2 and BS EN 60269-2 Bureau Veritas approved Height under front plate: 44mm Fix to DIN rail 4 EN 60715 or with screws SP 58 for HRC type aM and gG fuses 22 x 58Nominal voltage 400 V

Mounting method DIN rail

For fuse size 22x58 mm

Number of poles 1

Concurrently switching neutral conductor No

Degree of protection (IP) IP20

ETIM for 021601 Circuit breakers and fuses (EC002705)

Feature Name

Feature Value

For fuse size (EF008316)

22x58 mm

Degree of protection (IP) (EF005474)

IP20

Concurrently switching neutral conductor (EF005997)

No

Mounting method (EF000003)

DIN rail

Nominal voltage (EF000002)

400 V

Number of poles (EF001391)

1

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 021601 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.