

INDUSTRIAL COMPONENT DATA

091911 LEGRAND CONE TUBE DIAM. 25 MAXIMUM

Brand: LEGRAND | Manufacturer Part Number: 091911



Manufacturer	LEGRAND
MPN / Reference	091911
Catalog number	091911
Category	Cable entry sleeve
Minimum order	50 Pcs
Document ID	EO-04E2D700B8
Generated	2026-08-01

Product Overview

CONE TUBE DIAM. 25 MAXIMUM

Spare membrane gland Plexo - up to Ø25 - for box 105x105x55 mm

Cuttable replacement cone for Plexo boxes with inlet for tubes of max Ø25mm

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path LEGRAND > JUNCTION BOXES PLEXUS

Additional Product Information

Pack (number of units)50

Volume (dm3)1.39

Weight (g)231.00

Product characteristicsMembrane glands

Grey (RAL 7035)

With marking of Ø for tubes and cables

Up to Ø25

For wall fixing supplied with screws

General characteristicsPlexo™ boxes - accessories

ETIM for 091911 Cable glands and cable entry products (EC000879)

Feature Name

Feature Value

Suitable for cable diameter (EF005466)

4 mm

Angle model (EF005433)
No
For wall thickness (EF007789)
2.4 mm
Model (EF000010)
Closed
Bore diameter (EF007703)
27.5 mm
Degree of protection (IP) (EF005474)
Other
Material (EF002169)
Plastic
Halogen free (EF000025)
Yes
Material quality (EF001257)
Other
Suitable for cable gland (EF010872)
No
Operating temperature (EF001742)
-25 °C
Colour (EF000007)
Grey
Cable entry (EF000537)
Round
With strain relief (EF000878)
No

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send LEGRAND / 091911 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.